

MINIMUM 15# FELT PAPER

PRE-ENGINEERED TRUSSES
AT 24" ON CENTER

MIN. 7/16" ROOF SHEATHING
WITH PLYWOOD CLIPS
TABLE 503.2.1.1(1)

TRUSS TO WALL CONNECTION
TO RESIST UPLIFT OF NOT
LESS THAN 175 POUNDS
RCO SECTION 802.10.5

WALL BRACING PER
RCO SECTION R602.10

1/2" DRYWALL ON ALL COMMON
WALLS AND CEILING FOR ATTACHED
GARAGES. PROVIDE 5/8" TYPE "X"
IF HABITABLE ROOMS ARE ABOVE
RCO TABLE 302.6

2X STUD WALL
TABLE 602.3(5)

TREATED PLATE IF LESS
THAN 8" FROM GRADE
RCO SECTION 317.1(2)

3-1/2" THICK CONCRETE SLAB ON
GRADE (3,500 PSI CONCRETE WITH
AIR) OVER VAPOR BARRIER AND 4"
GRAVEL BASE
(AIR ENTRAINMENT TO BE FROM 5
TO 7 PERCENT MAX.) RCO 402.2

8"
MIN.

FINAL GRADE:
SLOPE 6" IN 10'
RCO SECTION
401.3


36" MINIMUM

1/2" ANCHOR BOLTS 72" ON CENTER, 12"
MAX. FROM CORNERS, 7" INTO BLOCK,
7" INTO CONCRETE
RCO SECTION 403.1.6

8" FOUNDATION WALL

8"

1'-4"



TYPICAL WALL SECTION

FOR GARAGE RCO 2013

SCALE: 3/4" = 1'-0"