



POLE CONSTRUCTION FOR ACCESSORY BUILDINGS

Plans for pole buildings with a maximum building width including overhangs of 36 feet RCO 324.1(5) may be submitted for approval without sealed engineering provided they meet the minimum requirements below.

1. Minimum depth to top of footing is 4 feet.
2. Minimum size for posts is 4"x6" solid or 3 ply laminated (RCO 324.4).
3. Maximum sidewall height is 16 feet (RCO 324.1(6)).
4. Maximum column spacing of 8'-0" (RCO 324.4.2)
5. Uplift protection (RCO 324.4(1))
6. Single story with no attic storage (RCO 324.1(2) and 324.1(4))
7. Knee bracing is provided (RCO 324.6)
8. Wall Bracing (RCO 324.4.6)

POLE-BARN CROSS SECTION

