



DECK PERIMETER

REMOVABLE DECK ACCESS
FOR TUB SERVICE
(NEC 110.26)

DISCONNECT MIN 5' FROM
INSIDE OF HOT TUB IN LINE
OF SITE FROM HOT TUB
(NEC 680.43 (C))

(HOT TUBS PLACED ON TOP OF DECK OR PLATFORM BELOW MAIN DECK REQUIRES 100 psf DECK DESIGN)

DECK WITH SUNKEN HOT TUB/ SWIM SPA, ELECTRICAL ACCESS REQUIREMENTS